

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1004:0119 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Apollo America Inc. 25 Corporate Dr., Auburn Hills, MI 48326
Contact: Richard Steele (248) 332-3900 Fax (248) 332-8807
Email: rsteele@ap-c.com

DESIGN: Models MSR-50RM/W, MSR-50RM/R, MSR-50RM/S, MSR-50RMS/W/C, MSR-50RMS/W/O, MSR-50RMS/R/C, MSR-50RMS//R/O, MSR-50RMS/S/C, MSR-50RMS/S/O, MSR-50RK/W, MSR-50RK/R, MSR-50RK/S, MSR-50RKS/W/C, MSR-50RKS/W/O, MSR-50RKS/R/C, MSR-50RKS/R/O, MSR-50RKS/S/C, and MSR-50RKS/S/O smoke-automatic fire detector accessories. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, electrical rating and UL label.

APPROVAL: Listed as smoke detectors accessories for use with listee's separately listed compatible RW Series, SM-501 Series, SL-2000 Series, 2650-560, and 2650-561 duct smoke detectors to provide audible and visual indication as well as remote test/reset functions..

NOTE: 1. Formerly Air Products and Controls, Inc.

10-29-2007 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division